

**FIRE SAFETY CERTIFICATE**

No.00170/RFO/FPW/GVMC/2021

Dated:12-06-2023

Certified that the Timpany Steel City School building at D.No.24-4-1, in Sy.No.17, Pedagantyada, Visakhapatnam comprised of Ground and three upper floors owned/occupied by M/s.Timpany Steel City School have complied with the fire prevention and fire safety requirements in accordance with the rule of A.P.State Fire Service Rules, and verified by the officers concerned of Fire Service on 26-07-2021 in presence of D.Yogesh, Timpany Steel City School building at D.No.24-4-1, in Sy.No.17, Pedagantyada, Visakhapatnam and that the building / premises is fit for occupancy up to classes X With effect from 29-06-2021 for a period of five (05) years in accordance with rule and subject to compliance of specific conditions as appended.

## 1) Particulars of The building:

a)	Address of the Premises	M/s.Timpany Steel City School, D.No.24-4-1 in Sy.No.17, Pedagantyada, Visakhapatnam
b)	Total Plot Area	20,267.13 Sq. Mtrs
c)	Height of the Building	12.43 Mtrs.
d)	No of blocks/ floors	01 Blocks / Ground + 03 Upper Floors
e)	Type of occupancy	Educational Building (School)

## 2) The floor wise details.

Sl. No.	Floor	Area in Sq. Meters.	Type of Occupancy
1.	Ground	2100	Educational (School)
2.	First	2100	Educational (School)
3.	Second	2100	Educational (School)
4.	Third	700	Educational (School)
	Total	7000	

## 3) Means Escape:

Sl. No.	Details of Staircase	Require Nos./ Mtrs.	Provided Nos./Mtrs.	From	To	Remarks / Deficit in Mtrs.
1	Internal	2 / 1.50	3 / 1.80 + 1.80 + 2.00 + = 5.60	Ground	Terrace	Nil

## 4) The Minimum Fire Safety Installations required &amp; provided by the Builder as per the Table -23 and other relevant clauses of part-4 of N.B.C of India 2005.

Sl. No	Fire Safety Measures	Required	Provided	Deficit
1	Fire Extinguishers as per IS 2190	70 Nos.	70 Nos.	Nil
2	Hose Reel	07 Nos.	14 Nos.	Nil
3	Down comer	02 Nos.	02 Nos.	Nil
4	Terrace Tank	10,000 Ltrs.	15,000 Ltrs.	Nil
5	Booster Pump	450 LPM	2No. of 450 LPM	Nil

Contd..page..2

Issued on 18-09-2021 at Visakhapatnam by Regional Fire Officer, Fire Prevention Wing, Greater Visakhapatnam Municipal Corporation, Visakhapatnam.

Signature with Seal :

*Choluvu 12/6/2023.*  
DISTRICT FIRE OFFICER  
FIRE PREVENTION WING  
Greater Visakhapatnam Municipal Corporation  
Visakhapatnam-530 002  
CH.KRUPAVARAM

Name

Designation

:Incharge Regional Fire Officer

Name & Address of Department / Office:

Fire Prevention Wing, 4<sup>th</sup> floor, GVMC Zone-IV  
office, Beside Venkateswara Theatre, Suryabagh,  
Visakhapatnam-530020.

To  
M/s. Timpany Steel City School, D.No.24-4-1,  
Sy.No.17, Pedagantyada, Visakhapatnam



*[Handwritten signature]*

**DIRECTOR  
TIMPANY SCHOOLS  
VISA KHAPATNAM-530 002**

*[Handwritten signature]*  
**PRINCIPAL  
TIMPANY STEEL CITY SCHOOL  
VISA KHAPATNAM-530 044**